

Government Of West Bengal Office Of The Divisional Fire Officer,North Dinajpur West Bengal Fire & Emergency Services Raiganj Fire Station, College Para, P.O.:- Raiganj, Pin :- 733134

Memo.no.:RFS/F/34/15

Date: 20-02-2021

From:

Divisional Fire Officer, North Dinajpur West Bengal Fire & Emergency Services

To: Chittaranjan Smriti Primary Teachers Training Institute
Uttar Goalpara, P.O.- Lahanda, P.S.- Raiganj, Dist.- Uttar Dirajpur. PIN- 733134

Sub: Renewal of Fire Safety Certificate for the G+2 storied Teacher training institute under group of Educational Building in the name of Chittaranjan Smriti Primary Teachers Training Institute Premises at Uttar Goalpara, P.O.-Lahanda, P.S.- Raiganj, Dist.- Uttar Dinajpur. PIN- 733134

This is in reference to your application no. 0125191210600014 dated 18-02-2021 regarding the Renewal of Fire Safety Certificate for the G+2 storied Teacher training institute under group of Educational Building in the name of Chittaranjan Smriti Primary Teachers Training Institute Premises at Uttar Goalpara, P.O.- Lahanda, P.S.- Raiganj, Dist.- Uttar Dinajpur. PIN- 733134

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Renewal of Fire Safety Certificate for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated / maintained.

Recommendation:

- 1. Driveway must be free of any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
- The Interior finish decoration of buildings shall be made with low flame spread material confirming to the I.S.
 Specification.
- 3.To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the buildings shall be strictly maintained.
- 4.Existing Electrical wiring of the whole buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
- 5.A Fire control room including a closed circuit TV system shall have to be maintained which observe all the floors of the

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the "Verification of Digitally Signed Document" link and keying in the Unique Number: 0125191210600014.

Page: 1

building.

- 6.The notice of Fire Fighting and Evacuation from the buildings shall be prepared and displayed at all vulnerable places of the Buildings.
- 7.The employees and security staff shall be conversant with installed fire fighting equipment of the buildings and to operate in the event of fire and testing.
- 8.Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the buildings.
- 9. Transformer and switch gear shall be protected with automatic CO2 or ABC Fire extinguishers confirming I.S. specifications.
- 10.A trained Fireman shall be maintained round the clock for fire safety of the building.
- 11. First Aid fire fighting system shall be provided as per I.S. specifications.
- 12.Arrangement shall have to be made for regular checking, testing, and maintenance of all the Fire Fighting installation in the Buildings to keep them in perfectly good working condition at all the times.
- 13.If required the old electrical lines shall have to be replaced with new lines. The cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
- 14. Electrical Ducts shall have to be sealed vertically and horizontally in proper manner immediately.
- 15.Periodical flashing of water in the Hydrants pipe line and sprinkler shall be made to maintain the efficient working performance of above mentioned system.
- 16. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance register.
- 17. Any deviation or non-compliance of additional safety system within the period the certificate may be treated as cancel.
- 18. This Renewal of Fire Safety Certificate is valid for Three year and has to be renewed every three year from the date of issue of this letter.
- 19. A certificate is to be obtained from the West Bengal Fire & Emergency Services regarding performance of all the Fire Safety arrangements and installations of the building.

Signature valid Signed by: MALAY CHOSH Resson: Appropria Location: Went Brigal Dister 20-Feb 2021 11:12:54

Divisional Fire Officer, North Dinajpur West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the "Verification of Digitally Signed Document" link and keying in the Unique Number: 0125191210600014.

Page: 2